



CIN: U40109RJ2000SGC016486

**JAIPUR VIDYUT VITRAN NIGAM LTD.**  
Office of Superintending Engineer (IT),  
Old Power House Premises, Near Ram Mandir,  
Jaipur-302006, Tel -0141-2205412

Regd. Office: Vidyut Bhawan, Jyoti Nagar, Jaipur 302005  
Website: [www.jaipurdiscom.com](http://www.jaipurdiscom.com), Email: [seitjvvn1@yahoo.in](mailto:seitjvvn1@yahoo.in)

No.JPD/SE(IT) /F-TN-61/D. 1486

Date: 27/01/2017

**Amendment TN-61**

Following amendment is hereby issued in said specification and its amendment for supply of GPRS Modems for Automated Meter Reading of Distribution Transformer in Jaipur Discom Jaipur against TN-61.

Clause No.	Existing Parameter	Particular's Amended as
Section III Part III , 1(xiii); Type Test	The GSM/GPRS modem shall be fully type tested at any NABL accredited test laboratories as per relevant standards. The bidder shall furnish two sets of type test reports along with the bid. The Type test reports shall not be more than three years old from the date of opening of bid. Beside above bidder should also submit the test report from CPRI, Bangalore/ Bhopal or ERDA along with the bid.	The GSM/GPRS modem shall be fully type tested from CPRI, Bangalore/Bhopal or ERDA or Govt. approved NABL laboratories viz. ERTL, NPL etc as per relevant standards. The bidder shall furnish two sets of type test reports along with the bid. The Type test reports shall not be more than three years old from the date of opening of bid.

27/1/2017  
Superintending Engineer (IT)